

TB 118

TECHNICAL BULLETIN

INFORMATION ONLY

For the Attention of : Service Engineers, Installers, Trade Customers, Training Dept
Date : 19th October 2011
Product : Midilift
Subject : Adjustable Door Contacts
Pages : 2

Originator : Stannah Lifts Ltd, Anton Mill, Andover, Hants SP10 2NX 01264 339090

Detail

Adjustable door contacts introduced for non-fire rated doors/gates, to aid installers and service engineers in pre/post installation adjustment.

Summary

With reference to the attached drawing please see below the following steps:

1. Slacken 4 x M5 tamper proof screws (item 9) and 2 x M4 c'sk skt hd screws (item 8).
2. Move contacts into required position. (please note the two contacts and hole lock move as one unit).
3. Tighten all 6 screws.
4. Close door and check the door lock bolt engages fully and the contacts are centred. *Tip: contacts can be checked by applying a felt pen to the opposite half. Close and open the door and look for the score line. Re-adjust if necessary.*



An independent family business since 1867

Stannah

