

TB 159

TECHNICAL BULLETIN

INFORMATION ONLY

For the Attention of : Service Engineers, Installers, Trade Customers, Training Dept
Date : 21st October 2016
Product : Midilift (SL, GL, SLplus & XLplus)
Subject : Changes to power closers on gates and fire doors.
Pages : 1

Originator : Stannah Lifts Ltd, Anton Mill, Andover, Hants SP10 2NX 01264 339090

A new closer has been introduced on powered operated gates and fire doors. The new closer, the Label Neptis, will replace the Ditec Wel UE used on powered fire doors due to the old unit becoming obsolete.

The new closer will also replace the Ditec Sprint used on powered gates, to address performance and reliability issues, encountered following changes made to the closer by the manufacturer.

These changes will affect lifts manufactured from 24/10/16

Notes:

- The closer comes with a spring to assist closing. The closer is supplied with this spring pre-tensioned and held in position by a locking screw. The screw must be left in position until the mechanical installation is complete.
- Do not power the closer until the mechanical installation has been completed and the locking screw removed.
- In the event the spring has been allowed to unwind, it will be necessary to reset the spring preload using the procedure described in the manufacturer's instructions.
- The closer requires a separate programmer (Stannah ref: 9449093) to facilitate setting up and adjustment.

For mechanical installation details, refer to the Midilift-SL installation guide.

For initial set-up details and default parameters, see the wiring manual.